



**SJVN Arun-3 Power Development Company (P) Ltd.**  
**Tumlingtar, Nepal**  
(Registration No: 111808/69/070)

No. SAPDC/CE(P&C)/Arun-3HEP/PPR-95/2020-72

**Dated:** 14.01.2020

**Amendment No. II**

**Sub:** Supply, transportation, fixing and demonstration of fire extinguishers in office and residential building of SAPDC at Tumlingtar, Dovan , Phaksinda, Pukhuwa & Janakpur in Nepal (**PPR-95**).

Following amendments are hereby authorized in the Tender documents of the subject cited tender uploaded on websites (<http://sjvn.nic.in> & <https://sapdc.com.np>) w.e.f. 01.01.2020:

Sr. No	Clause Ref.	To be read/modified as
<b>Technical Specification (PPR-95)</b>		
1.	Sr.No.1, ABC Type Fire Extinguishers, 4 Kg.	<i>Working Temperature is modified as: -10°C to +55°C</i>
2.	Sr.No.2, ABC Type Fire Extinguishers, 6 Kg.	<i>Working Temperature is modified as: -10°C to +55°C</i>
3.	Sr.No.3, ABC Type Fire Extinguishers, 9 Kg.	<i>Working Temperature is modified as: -10°C to +55°C</i>
4.	Sr.No.4, CO2 Type Fire Extinguishers, 2 Kg.	<i>Working Temperature is modified as: -20°C to +55°C</i>
5.	Sr.No.5, CO2 Type Fire Extinguishers, 5 Kg.	<i>Working Temperature is modified as: -20°C to +55°C</i>

**All other terms & conditions shall remain unchanged.**

For & on the behalf of SAPDC

Sd/  
**Chief Engineer (P&C)**  
Satluj Bhawan, Arun Sadan,  
SAPDC, Tumlingtar,  
Distt. Sankhuwasabha, Nepal  
Ph. +977-29-575154,  
E-mail Address: pnc.sapdc@gmail.com